



Certificate of Conformity

LOVAG-Certificate No.: IT 17.045 Page 1 of 1

Apparatus

Low voltage switchgear assembly

400V (Ue) 690V(Ui) 8kV(Uimp) 4000A(InA) 50Hz

(f) 100kA(Icc) x 3s IP 3X

This Certificate applies only to the apparatus verified. The responsibility for conformity of any apparatus having the same designation with that verified rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Prin-

ciples of mutual recognition.

The responsible certification body as a member of LOVAG issues a Certificate of Conformity with the above mentioned

Only integral reproduction of this Certificate or reproductions of this page accompanied by

Standard(s) following the exclusive use of LOVAG

any page(s) on which are stated the verifications

performed and the assigned

rated characteristics of the apparatus verified, are

permitted without written permission from the LOVAG

Signatory responsible for this

Certificate

Verification instruction

wherever applicable.

Designation Type

UNIPOWER

Manufacturer

SCAE S.r.L.

Via Enrico fermi 8/10-24050 Grassobbio (BG) Italy

Applicant:

SCAE S.r.L.

Via Enrico fermi 8/10-24050 Grassobbio (BG) Italy

Verified by:

Laboratory ACAE II01

The apparatus, constructed in accordance with the description mentioned in the Report(s) listed in this Certificate has been subjected to the series of proving verifications in accordance with

IEC 61439-2 ed.2.0 (2011-08)

The results are shown in the Report(s) in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated in the following.

10.10 Temperature-rise 4000A

10.11 Short circuit withstand strength 100kA x 3s

10.5.3 Short circuit withstand strength of the protective circuit 63kA

This document includes:

Test Report No.: 17-0164-01

Issue Date: 2017.03.28



Authorized Signature: Virginio Scarioni

Responsible Certification Body: ACAE Via Tito Livio, 5 - 24123 - BERGAMO (Italy)

Date: 2017.06.15

MOD 007 pag 1 Revi