

Test report NO.. 17-0164-01

Test laboratory(ies) : Istituto Nazionale di Ricerca Metrologica (I.N.Ri.M.)
STALT-ST1 LATFC laboratory ACAE (code II.01)
Corso Massimo d'Azeglio, 42 - 10125 Torino

Applicant : SCAE S.r.L.

Manufacturer : SCAE S.r.L.

Test object : Low voltage switchgear assembly

Type designation : UNIPOWER

Date(s) of test(s) : from 2017/03/03 to 2017/03/07

Standard for test : IEC 61439-2: Ed. 2.0 (2011-8)

: EN 61439-2: 2011-8

Test sequence(s) : subclauses 10.10, 10.11, 10.5.3

Test results: : found in compliance with the rated characteristics

This Test Report consists of:
18 pages LOVAG test report forms and
14 other pages

All the measurement uncertainties are
within the limits of LOVAG General
Instruction G2 – Measurement Uncertainties

Date of issue: 2017/03/28

Authorized Representative of Lovag Certification Body

Name: Ernani Besana

Function: ACAE Inspector

Signature: 

Responsible of the Test Laboratory

Name: Luca Cinnirella

Function: Responsible laboratory II.01

Signature: 

Note: The test result relates only to the items tested.
The test report shall not be reproduced except in full
without the written approval of the test laboratory

TRF IEC/EN 61439-2
Ed. 2.0c form 1